



BULGARKONTROLA

BULGARKONTROLA SA -Sofia

Conformity Assessment Body for Construction Products

With identification number 14 and Permit № ПОССП-14 on 15.09.2016

Issued by Ministry of Regional Development and Public Works

CERTIFICATE OF CONFORMITY

14 – HYPBCIIICPB – 4294

Issued pursuant to Art. 14, par 1 and par.2 of the Regulation № ПД-02-20-1 on 05.02.2015 on the terms and conditions for use of construction products in the construction of the Republic of Bulgaria on Ministry of Regional Development and Public Works for the **construction product**

HDPE POLYETHYLENE PIPES “KUZEYBORU”

with structured –wall piping system

with smooth internal and profiled external surface type “B”,

Intended for the construction of pressureless underground external drainage, drainage and wastewater disposal code “U”, with dimensions, ring stiffness and evaluated characteristics in accordance with national requirements as per Supplement № 1 to this Certificate.

place on the market by

KUZEY BORU A.Ş.

Kırımlı OSB Mahallesi Mehmetçik Bulvari № 2/1

Merkez/Aksaray, Türkiye

manufactured by

KUZEY BORU A.Ş.

Kırımlı OSB Mahallesi Mehmetçik Bulvari № 2/1

Merkez/Aksaray, Türkiye

This certificate certifies that the product has been evaluated and meets national requirements set out in

BDS EN EN 13476-3:2025

*and item 12 of Annex 2 to item 2 of Order № 02-14-1329 from 03.12.2015
of the Minister of Regional Development and Public Works*

The certificate was issued for first time on **20/07/2026**

and remains valid for three years until **19/07/2029**


provided the manufacturer ensures consistency of product characteristics and the conditions of production or production control has not been changed significantly.

Place: Sofia

Date: 20/07/2026

Director of "Conformity Assessment" Dept.

/T. Lyubenova/





Supplement № 1
to Certificate of Conformity № 14– HYPBCПCРБ-4294

1. Nominal dimension and Stiffness

Nominal dimension DN/ID	Stiffness SN (kN/m ²)
ID 100 , ID 125, ID 150, ID 200, ID 225, ID 250, ID300, ID400, ID500, ID600, ID800, ID 1000	SN4
ID 100 , ID 125, ID 150, ID 200, ID 225, ID 250, ID300, ID400, ID500, ID600, ID800, ID 1000	SN8

2. Evaluated characteristics in accordance with national requirements

Characteristics	Requirement to declare / border level
Appearance	Smooth and clean surface without pores, According to item 6.1 of BDS EN 13476-1:2025
Color	External layer : black; Internal layer: white – grey, blue, green, red, yellow According to item 6.2 of BDS EN 13476-1:2025
Geometrical characteristics, mm – mean external diameter, $d_{em,min}$	DN/ID 100÷1000 According to item 8,2 , tables 5,6 and . 7 of BDS EN 13476-1:2025
Oven of test – test temperature 110 ⁰ C	Without delimitation, cracking and bubbles. According to item. 9.3.1., table12 of BDS EN 13476-3:2025
Ring stiffness SN, kN/m ²	≥ declared value for SN According to item 10.1.1, table 14 of BDS EN 13476-3:2025
Ring flexibility, kN	without damage , min. 30 % or d_{em} , According to item 10.1.2, table14 of BDS EN 13476-3:2025
Leaktightness of systems with elastomeric seating rings	No leakage during the test According to item 11, table17 of BDS EN 13476-3:2025

Place: Sofia
Date: 20/07/2026

Director of "Conformity Assessment" Dept.

/T. Lyubenova/

