



CERTIFICATE OF CONFORMITY

UYGUNLUK SERTİFİKASI

TÜV
AUSTRIA

Certificate No / Sertifika No. : 26-IS-0655-TAT-COC-0236

Applicant Başvuru Sahibi	: Kuzey Boru Anonim Şirketi Kırımlı OSB Mah. Mehmetçik Bulvarı No: 2 Merkez, Aksaray, Türkiye
Manufacturer Üretici	: Kuzey Boru Anonim Şirketi Kırımlı OSB Mah. Mehmetçik Bulvarı No: 2 Merkez, Aksaray, Türkiye
Product Ürün	: Glass Fiber Reinforced PP-RCT Composite Pipe
Brand Name/Trade Mark Ticari Marka	: kuzeyboru
Type/Model(s) Tip/Model(ler)	: Layer Materials: Inner: PP-RCT, Middle: Fiberglass Reinforced PP-RCT, Outer: PP-RCT Pipe Series: S 2,5 Application Class: Class 1 Operating Pressure: 8 Bar up to 10 Bar Nominal Outside Diameter: 20 mm up to 63 mm Impact Resistance: Not Applicable
Standard(s) / Certification Basis Standart(lar)/Yönetmelik(ler)	: EN ISO 15874-2:2013/A2:2022 Plastics piping systems for hot and cold water installations - Polypropylene (PP) – Part 2: Pipes

This Certificate of Conformity is issued on a voluntary basis according to EN ISO 15874-2:2013/A2:2022 standard. It conforms that the product(s) & manufacturer's quality control system comply with the essential requirements of the standard. It refers only to the sample and its technical file submitted for conformity assessment in conjunction with the internal factory production control system assessment.

Bu uygunluk değerlendirme sertifikası EN ISO 15874-2:2013/A2:2022 standardına göre gönüllük esasına göre verilmiştir. Yukarıda belirtilen ürün(ler)in ve üreticinin kalite kontrol sisteminin standardın temel gerekliliklerine uygun olduğunu belirtir. Uygunluk değerlendirilmesi başvuruda sunulan ürün, teknik dosyası ve fabrika iç üretim kontrol sistemi üzerinden yapılmıştır.

Ref. Inspection Report No : 26-IS-0665-TAT-26-IR-0001
Ref. Denetim Rapor No.

First Issual Date : 22.04.2026
İlk Denetim Tarihi

Next Surveillance Date : 21.04.2027
Bir Sonraki Denetim Tarihi

Expiry Date : 21.04.2029
Geçerlilik Tarihi

This Certificate has been granted to the applicant based on the results of testing performed by the applicant/manufacturer or an accepted laboratory and the consequent review of the test report by TÜV Austria Turk. Revisions to the referenced certification basis or any change of the design, materials, components or processing, manufacturing address may require the repetition of all or some of the qualification tests in order for the test report and therefore this associated certificate to remain valid.

Bu Uygunluk Sertifikası, başvuru sahibi/üretici tarafından veya kabul gören bir laboratuvar tarafından yapılan test sonuçlarına ve TÜV AUSTRIA TURK'un müteakip incelemesine dayanılarak başvuru sahibine verilmiştir. Bahsi geçen belgelendirme dayanağındaki değişiklikler veya tasarım, malzemeler, bileşenler veya işlemedeki değişiklikler, test raporunun ve dolayısıyla bu ilişkili sertifikanın geçerli kalması için nitelik testlerinin tamamının veya bir bölümünün tekrarlanması gerektirebilir.

Location / Yer**Date / Tarih**

Ankara

22.04.2026

Yusuf Erdoğan
Approved for and behalf of
TÜV AUSTRIA TURK Belgelendirme
Eğitim ve Gözetim Hizmetleri Ltd. Şti